



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Joseph Sbarra
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005**

10/27/2016

Phone: (212) 612-7900
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/21/2016. The results are tabulated on the attached data pages for the following client designated project:

Peekskill Schools Lead Testing / 2041420.038.00

The reference number for these samples is EMSL Order #011607001. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011607001
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: **Peekskill Schools Lead Testing / 2041420.038.00**

Analytical Results

Client Sample Description PMS-01
 3-ICE-GYM STORAGE AREA **Collected:** 10/20/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-02
 3-ICE-KITCHEN **Collected:** 10/20/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-03
 3-S-KITCHEN HANDWASH NEAR LOCKER RM **Collected:** 10/20/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.1	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description **PMS-04**
3-S-KITCHEN ACROSS STOVE **Collected:** 10/20/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	31.8	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-05
 3-S-KITCHEN NEAR OVEN **Collected:** 10/20/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.59	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-07
 3-S-KITCHEN WASH SINK L **Collected:** 10/20/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.45	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-08
 3-S-KITCHEN WASH SINK R **Collected:** 10/20/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.65	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011607001
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: **Peekskill Schools Lead Testing / 2041420.038.00**

Analytical Results

Client Sample Description PMS-09
 3-S-KITCHEN HADNWASH NEAR WALK
 IN FREEZER
Collected: 10/20/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.77	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-10
 3-S-KITCHEN SERVICE AREA NEAR
 KITCHEN LOCKER ROOM
Collected: 10/20/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.31	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-11
 S-SERVING AREA NEAR KITCHEN
 OVENS
Collected: 10/20/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.41	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-12
 3-S-RM 301A TEACHERS LOUNGE
Collected: 10/20/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.68	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-13
 3-F-OUTSIDE CAFETERIA
Collected: 10/20/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-15
 3-S-RM 312 WINDOWS L
Collected: 10/20/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-16
 3-S-RM 312 WINDOWS R
Collected: 10/20/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011607001
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: **Peekskill Schools Lead Testing / 2041420.038.00**

Analytical Results

Client Sample Description PMS-17
 3-S-RM 316 NEAR RM ENTRANCE **Collected:** 10/20/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.23	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-18
 3-S-RM 316 NEAR TEACHER DESK **Collected:** 10/20/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.03	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-19
 3-S-RM 317 **Collected:** 10/20/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.29	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-20
 3-S-RM 318 L NEAR TEACHER DESK **Collected:** 10/20/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.49	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-21
 3-S-RM 318 R **Collected:** 10/20/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.11	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-22
 3-S-RM 326 **Collected:** 10/20/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.47	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-23
 3-S-RM 328 WINDOWS L **Collected:** 10/20/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.45	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011607001
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: **Peekskill Schools Lead Testing / 2041420.038.00**

Analytical Results

Client Sample Description PMS-24
 3-S-RM 328 WINDOWS R **Collected:** 10/20/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-25
 3-S-RM 328 WALL L **Collected:** 10/20/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.82	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-27
 4-F-OUTSIDE 403 / LIBRARY BR'S **Collected:** 10/20/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-28
 2-F-SWIMMING POOL L **Collected:** 10/20/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-29
 2-F-SWIMMING POOL R **Collected:** 10/20/2016 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-30
 2-S-RM 216 WINDOWS L **Collected:** 10/20/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.55	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-31
 2-S-RM 216 WINDOWS R **Collected:** 10/20/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.66	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011607001
 CustomerID: LBAP78
 CustomerPO:
 ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: **Peekskill Schools Lead Testing / 2041420.038.00**

Analytical Results

Client Sample Description PMS-32
 2-S-RM 216 WALL L **Collected:** 10/20/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.7	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-33
 2-S-RM 216 WALL R **Collected:** 10/20/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.9	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-34
 2-S-RM 232 WINDOWS R **Collected:** 10/20/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.35	1.00	µg/L	10/26/2016	JS	10/27/2016	JS

Client Sample Description PMS-35
 2-S-RM 232 WALL L **Collected:** 10/20/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.05	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-36
 2-S-RM 232 WALL R **Collected:** 10/20/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.71	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-37
 1-S-RM 118 WINDOWS L **Collected:** 10/20/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.49	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-38
 1-S-RM 118 WINDOWS R **Collected:** 10/20/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.05	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607001

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.038.00

Analytical Results

Client Sample Description PMS-39
 1-S-RM 118 WALL L **Collected:** 10/20/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.85	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-40
 1-S-RM 118 WALL R **Collected:** 10/20/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.05	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PMS-41
 1-S-RM 126 WINDOW L **Collected:** 10/20/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.03	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)